



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802


Corvallis, OR Microbiology/Chemistry (d)  
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

## INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Sandy Point Improvement Co.

Reference Number: 20-34307  
Project: Water Test

Date Collected: 9/27/20 14:30  
System ID Number:  
Lab Number: **046-65095**  
Sample Location: Agate Lake  
Sample Purpose: Investigative or Other  
Sample Composition:  
Approved by: bj,bsp  
Authorized by:   
Lawrence J Henderson, PhD  
Director of Laboratories, Vice President

Field ID:  
System Group Type:  
System Name:  
County:  
Source Number:  
Multiple Sources:  
Date Received: 9/29/20  
Report Date: 10/16/20  
Sample Type:  
Sampled By:  
Sampler Phone:

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
22	<b>EPA Regulated (Secondary)</b> SULFATE	<b>49.4</b>	mg/L	1			srs	300.0	a	09/30/20	
23	<b>State Unregulated</b> COPPER	<b>0.0061</b>	mg/L	0.002		1.3	bj	200.8	a	10/14/20	

**NOTES:**

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).  
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.  
Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.  
ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).

If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.